


10/18/2023



957-5402.0.1

REVISIONS				GENERAL NOTES				DRAWING TITLE			
NO.	DATE	BY	DESCRIPTION								
				CEILING HEIGHT = 96'-00"				DRAWING TITLE			
				REFER TO DDP#1A PRICE MP#-2.0 FOR AREA LIGHT & VENT				MASTER PLAN #2			
				REFER TO DDP#1A PRICE EL-1.2 FOR ELEC. SYMBOL & BRANCH CIRCUIT NUMBER				2 BEDROOM OPTION			
				TOTAL WINDOW SFT = 122 STD / 107 W/ PATIO/TERRACE							
BRAND	CLAYTON	SERIES	HR16								
MODEL NAME	5402			RETURN AIR REQUIREMENTS				INDICATES REQUIRED NUMBER OF STUDS IN COLUMN			
PLANT	957	DESCRIPTION	16X66 3BR-2BR	① 20"x16" GRILL REQUIRED				① THE # SPECIFIES THAT THERE CAN BE NO HOLES IN STUDS IN COLUMNS			
DRAWN BY	KLK	ORIG. DATE	06/06/2023	② 4"x10" GRILL W/ 2 1/2" DOOR UNDERCUT							
DATE PRINTED	10/17/2023			③ DOOR(S) MUST BE UNDERCUT 2 1/2" MIN.							
SHEET NO.	1-2			④ 4"x24" OR 6"x14" GRILL REQUIRED							

CMH Inc.
SHEARWALL DESIGN - HUD



Model # 5402
 Box Width = 180 " Single wide Minimum Joist Spacing 16 "
 Box Length = 66 ft. 99.5" 10" MIN.IBEAM No Offset Box
 No Skylights No Clerestory No Origami Dormer
 No Porches No Sunken Floor
 Joist Size = #2 spf 2x6 Lags 9Mx3" No Parapet Roof

Version R13.20

Wind Zone 1 Standard Roof							96 inch sidewall	
(3/8" sheathing only with 16ga. @ 4/8 oc) [132 plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.								
Diaphragm Construction:								
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	
A	0'	92"	420	5	2/2	Split Shearwall	46/46	
B	66'	141"	210	2	2/2	Split Shearwall	105/36	
Wind Zone 2 Standard Roof							96 inch sidewall	
(3/8" sheathing w/ceiling with 16ga. @ 4/8 oc) [232 plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.								
Diaphragm Construction:								
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	
A	0'	92"	420	5	2/2	Split Shearwall	46/46	
B	66'	141"	210	2	2/2	Split Shearwall	105/36	
C	23.25'	120"	350	3	3/1			
D	44.42'	120"	350	3	3/1			
Wind Zone 3 Standard Roof							96 inch sidewall	
(3/8" sheathing w/ceiling with 16ga. @ 4/8 oc) [232 plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.								
Diaphragm Construction:								
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	
A	0'	92"	420	5	2/2	Split Shearwall	46/46	
B	66'	141"	210	2	2/2	Split Shearwall	105/36	
C	23.25'	120"	420	3	4/1			
D	44.42'	120"	420	3	4/1			
Wind Zone 4 Standard Roof							96 inch sidewall	
(3/8" sheathing only with 14ga. @ 6/6 oc) [172 plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.								
Diaphragm Construction:								
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	

Designed by KLK

957-5402.0.2

Model # 5402 (2 BEDROOM OPT)

Box Width =	180 "	Single wide	Minimum Joist Spacing 16 "
Box Length =	66 ft.	99.5" 10" MIN.IBEAM	No Offset Box
No Skylights			No Clerestory
No Porches			No Origami Dormer
Joist Size =	#2 spf 2x6	Lags 9Mx3"	No Sunken Floor
			No Parapet Roof

Version R13.20


Wind Zone 1 Standard Roof							(3/8" sheathing only with 16ga. @ 4/8 oc) [132] 96 inch sidewall	
Diaphragm Construction:							plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.	
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	
A	0'	92"	420	5	2/2	Split Shearwall	46/46	
B	66'	141"	210	2	2/2	Split Shearwall	105/36	
Wind Zone 2 Standard Roof							(3/8" sheathing w/ceiling with 16ga. @ 4/8 oc) 96 inch sidewall	
Diaphragm Construction:							[232 plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.	
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	
A	0'	92"	420	5	2/2	Split Shearwall	46/46	
B	66'	141"	210	2	2/2	Split Shearwall	105/36	
C	26'	120"	350	3	3/1			
D	42.5'	120"	350	3	3/1			
Wind Zone 3 Standard Roof							(3/8" sheathing w/ceiling with 16ga. @ 4/8 oc) 96 inch sidewall	
Diaphragm Construction:							[232 plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.	
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	% over
A	0'	92"	420	5	2/2	Split Shearwall	46/46	
B	66'	141"	210	2	2/2	Split Shearwall	105/36	
C	26'	120"	420	3	4/1			
D	42.5'	131"	350	3	3/1			0.76
Wind Zone 4 Standard Roof							(3/8" sheathing only with 14ga. @ 6/6 oc) [172] 96 inch sidewall	
Diaphragm Construction:							plf] Chords: 2x4 SPF #3 Top Plate & 2x4 Rail. Each spliced w/ 12" glue block.	
Shearwall	Dist./ Hitch	Length	PLF	# of Joists	Lags	Notes	SW1/SW2	% over

Designed by KLK

957-5402.0.3

HOT WATER MDL'S
 3/4" MDL = 9ft
 1/2" MDL = 4ft
 VOLUME (gal) = .54

APPROVED BY
NIA INC.
 FEDERAL MANUFACTURED HOME
 CONSTRUCTION AND SAFETY STANDARDS
 10/18/2023



HOT WATER SUPPLY PLUMBING

COLD WATER SUPPLY PLUMBING


957-5402.1

PIPE LEGEND

	1"
	3/4"
	1/2"

BRAND CLAYTON	SERIES HR16	DRAWING TITLE SUPPLY PLUMBING		MODEL NAME 5402	SO. FT. 990
		GENERAL NOTES HOSE BIBBS PER SPECS		PLANT 957	DESCRIPTION 16X66 3BR-2BA
CLAYTON HOME BUILDING GROUP		REVISIONS	DATE	DATE PRINTED 10/13/2023	SHEET NO. 9-1
		BY	DATE	ORIG. DATE 06/06/2023	MODEL NO. 5402

HOT WATER MDL'S
 3/4" MDL = 12ft
 1/2" MDL = 36ft
 VOLUME (gal) = .55



PIPE LEGEND

=====	1"
=====	3/4"
=====	1/2"

HOT WATER SUPPLY PLUMBING


COLD WATER SUPPLY PLUMBING

957-5402.1.1

BRAND CLAYTON	SERIES HR16	DRAWING TITLE		MODEL NAME 5402	SQ. FT. 990
		GENERAL NOTES		PLANT 957	MODEL NO. 5402
CLAYTON HOME BUILDING GROUP		SUPPLY #2 2 BEDROOM OPTION		DESCRIPTION 16X66 3BR-2BA	DATE PRINTED 10/13/2023
REVISIONS		DATE	BY	DATE	SHEET NO. 9-2
HOSE BIBBS PER SPECS				ORIG. DATE 06/06/2023	

PIPING AND FITTING MATERIAL TYPE TO BE:
 ABS (ACRYLONITRILE-BUTADIENE-STYRENE)
 OR PVC (POLYVINYL CHLORIDE)

PIPE LEGEND




V.I.R.

V.I.R.

APPROVED BY
NTA INC.
 10/18/2023
 FEDERAL MANUFACTURED HOME
 CONSTRUCTION AND SAFETY STANDARDS

STANDARD SHIP LOOSE	
AO	I
D	I
E	I
EE	I
U	I
W	I
1.5" PIPE	25 FT
2" PIPE	5 FT
3" PIPE	25 FT



USE FOR STANDARD LAYOUT AND OPTIONAL 2 BEDROOM LAYOUT


LET	DESCRIPTION	LET	DESCRIPTION	LET	DESCRIPTION	LET	DESCRIPTION
C	1.5" x 90° LSWEEP 1/4" BEND	P	3" x 90° LSWEEP 1/2" BEND	AA	3" x 45° WYE	BB	3" x 45° WYE
D	2" x 90° LSWEEP 1/4" BEND	Q	3" x 90° LSWEEP 1/2" BEND	BB	3" x 45° WYE	CC	3" x 45° WYE
E	3" x 90° LSWEEP 1/2" BEND	R	3" x 90° LSWEEP 1/2" BEND	CC	3" x 45° WYE	DD	3" x 45° WYE
F	3" x 90° LSWEEP 1/2" BEND	S	3" x 90° LSWEEP 1/2" BEND	DD	3" x 45° WYE	EE	3" x 45° WYE
G	3" x 90° LSWEEP 1/2" BEND	T	3" x 90° LSWEEP 1/2" BEND	EE	3" x 45° WYE	FF	3" x 45° WYE
H	3" x 90° LSWEEP 1/2" BEND	U	3" x 90° LSWEEP 1/2" BEND	FF	3" x 45° WYE	GG	3" x 45° WYE
I	3" x 90° LSWEEP 1/2" BEND	V	3" x 90° LSWEEP 1/2" BEND	GG	3" x 45° WYE	HH	3" x 45° WYE
J	3" x 90° LSWEEP 1/2" BEND	W	3" x 90° LSWEEP 1/2" BEND	HH	3" x 45° WYE	II	3" x 45° WYE
K	3" x 90° LSWEEP 1/2" BEND	X	3" x 90° LSWEEP 1/2" BEND	II	3" x 45° WYE	JJ	3" x 45° WYE
L	3" x 90° LSWEEP 1/2" BEND	Y	3" x 90° LSWEEP 1/2" BEND	JJ	3" x 45° WYE	KK	3" x 45° WYE
M	3" x 90° LSWEEP 1/2" BEND	Z	3" x 90° LSWEEP 1/2" BEND	KK	3" x 45° WYE	LL	3" x 45° WYE
N	3" x 90° LSWEEP 1/2" BEND	AA	3" x 90° LSWEEP 1/2" BEND	LL	3" x 45° WYE	MM	3" x 45° WYE
O	3" x 90° LSWEEP 1/2" BEND	AB	3" x 90° LSWEEP 1/2" BEND	MM	3" x 45° WYE	NN	3" x 45° WYE
P	3" x 90° LSWEEP 1/2" BEND	AC	3" x 90° LSWEEP 1/2" BEND	NN	3" x 45° WYE	OO	3" x 45° WYE
Q	3" x 90° LSWEEP 1/2" BEND	AD	3" x 90° LSWEEP 1/2" BEND	OO	3" x 45° WYE	PP	3" x 45° WYE
R	3" x 90° LSWEEP 1/2" BEND	AE	3" x 90° LSWEEP 1/2" BEND	PP	3" x 45° WYE	QQ	3" x 45° WYE
S	3" x 90° LSWEEP 1/2" BEND	AF	3" x 90° LSWEEP 1/2" BEND	QQ	3" x 45° WYE	RR	3" x 45° WYE
T	3" x 90° LSWEEP 1/2" BEND	AG	3" x 90° LSWEEP 1/2" BEND	RR	3" x 45° WYE	SS	3" x 45° WYE
U	3" x 90° LSWEEP 1/2" BEND	AH	3" x 90° LSWEEP 1/2" BEND	SS	3" x 45° WYE	TT	3" x 45° WYE
V	3" x 90° LSWEEP 1/2" BEND	AI	3" x 90° LSWEEP 1/2" BEND	TT	3" x 45° WYE	UU	3" x 45° WYE
W	3" x 90° LSWEEP 1/2" BEND	AJ	3" x 90° LSWEEP 1/2" BEND	UU	3" x 45° WYE	VV	3" x 45° WYE
X	3" x 90° LSWEEP 1/2" BEND	AK	3" x 90° LSWEEP 1/2" BEND	VV	3" x 45° WYE	WW	3" x 45° WYE
Y	3" x 90° LSWEEP 1/2" BEND	AL	3" x 90° LSWEEP 1/2" BEND	WW	3" x 45° WYE	XX	3" x 45° WYE
Z	3" x 90° LSWEEP 1/2" BEND	AM	3" x 90° LSWEEP 1/2" BEND	XX	3" x 45° WYE	YY	3" x 45° WYE
AA	3" x 90° LSWEEP 1/2" BEND	AN	3" x 90° LSWEEP 1/2" BEND	YY	3" x 45° WYE	ZZ	3" x 45° WYE
AB	3" x 90° LSWEEP 1/2" BEND	AO	3" x 90° LSWEEP 1/2" BEND	ZZ	3" x 45° WYE	AAA	3" x 45° WYE
AC	3" x 90° LSWEEP 1/2" BEND	AP	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AD	3" x 90° LSWEEP 1/2" BEND	AQ	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AE	3" x 90° LSWEEP 1/2" BEND	AR	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AF	3" x 90° LSWEEP 1/2" BEND	AS	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AG	3" x 90° LSWEEP 1/2" BEND	AT	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AH	3" x 90° LSWEEP 1/2" BEND	AU	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AI	3" x 90° LSWEEP 1/2" BEND	AV	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AJ	3" x 90° LSWEEP 1/2" BEND	AW	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AK	3" x 90° LSWEEP 1/2" BEND	AX	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AL	3" x 90° LSWEEP 1/2" BEND	AY	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AM	3" x 90° LSWEEP 1/2" BEND	AZ	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AN	3" x 90° LSWEEP 1/2" BEND	BA	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AO	3" x 90° LSWEEP 1/2" BEND	BB	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AP	3" x 90° LSWEEP 1/2" BEND	BC	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AQ	3" x 90° LSWEEP 1/2" BEND	BD	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AR	3" x 90° LSWEEP 1/2" BEND	BE	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AS	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AT	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AU	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AV	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AW	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AX	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AY	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
AZ	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
BA	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
BB	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
BC	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
BD	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
BE	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE
BF	3" x 90° LSWEEP 1/2" BEND	BF	3" x 90° LSWEEP 1/2" BEND	AAA	3" x 45° WYE	AAA	3" x 45° WYE

957-5402.2

DRAWING TITLE		MODEL NAME		MODEL NO.		SQ. FT.	
DWY SCHEMATIC		957		5402		990	
GENERAL NOTES		PLANT		DESCRIPTION		MODEL NO.	
		957		16X66 3BR-2BA		5402	
REVISIONS		DRAWN BY		DATE PRINTED		SHEET NO.	
		KLK		06/06/2023		10/13/2023	
BY		DATE		DATE PRINTED		SHEET NO.	
						8-1	
BRAND		SERIES		CLAYTON		HR16	
CLAYTON		HR16		CLAYTON HOME BUILDING GROUP			



Level 1



APPROVED BY
NIA INC. 10/18/2023
FEDERAL MANUFACTURED HOME
CONSTRUCTION AND SAFETY STANDARDS

957-5402.4.1

Job #: 5402(I)
Performed by CLAYTON ROCKWELL for:
5402(I)
ROCKWELL, NC

Scale: 1 : 110
Page 1
Right-Suite© Universal 2023
23.0.04 RSU28035
2023-Oct-11 09:43:59
R:\WRITESOFT\MODELS\5402(I).rup

Project Information

For: 5402(I), CLAYTON 957
 ROCKWELL, NC

Notes: DUCT COOLING CAPACITY = 26,000 BTU/HR

APPROVED BY



Design Information

Weather: Fort Bragg/Simmons, NC, US

Winter Design Conditions

Outside db 26 °F
 Inside db 70 °F
 Design TD 44 °F

Summer Design Conditions

Outside db 95 °F
 Inside db 75 °F
 Design TD 20 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 41 gr/lb

Heating Summary

Structure 12739 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **2892** Btuh
Outside air
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 15630 Btuh

Sensible Cooling Equipment Load Sizing

Structure 11105 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **1289** Btuh
Outside air
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 1.00
 Equipment sensible load 12357 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	990	990
Volume (ft ³)	8239	8239
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	68	38

Latent Cooling Equipment Load Sizing

Structure 1847 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **1644** Btuh
Outside air
 Equipment latent load 3490 Btuh
Equipment Total Load (Sen+Lat) 15847 Btuh
 Req. total capacity at 0.70 SHR 1.5 ton

Heating Equipment Summary

Make Smart Comfort
 Trade
 Model
 AHRI ref

Efficiency 100 EFF
 Heating input 10.0 kW
 Heating output 34121 Btuh
 Temperature rise 40 °F
 Actual air flow 780 cfm
 Air flow factor 0.061 cfm/Btuh
 Static pressure 0.30 in H2O
 Space thermostat

Cooling Equipment Summary

Make Smart Comfort
 Trade 15 SEER2 AC
 Cond R4A5S24*K*WAA*
 Coil FEVA0024***+NAVA43601CK
 AHRI ref 0
 Efficiency 13.0 EER2, 15.5 SEER2
 Sensible cooling 16380 Btuh
 Latent cooling 7020 Btuh
 Total cooling 23400 Btuh
 Actual air flow 780 cfm
 Air flow factor 0.070 cfm/Btuh
 Static pressure 0.30 in H2O
 Load sensible heat ratio 0.78

957-5402.4.2

Bold/italic values have been manually overridden


Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



APPROVED BY

NIA INC. 10/18/2023
FEDERAL MANUFACTURED HOME
CONSTRUCTION AND SAFETY STANDARDS

Level 1



957-5402.4.3

Job #: 5402_2BR_OPT(I)
Performed by CLAYTON ROCKWELL for:
5402_2BR_OPT(I)
ROCKWELL, NC

Scale: 1 : 110
Page 1
Right-Suite© Universal 2023
23.0.04 RSU28035
2023-Oct-10 15:43:38
...omes\Desktop\5402_2BR_OPT(I).r

Project Information

For: 5402_2BR_OPT(I), CLAYTON 957
 ROCKWELL, NC

Notes: DUCT COOLING CAPACITY = 26,000 BTU/HR

APPROVED BY



Design Information

Weather: Fort Bragg/Simmons, NC, US

Winter Design Conditions

Outside db 26 °F
 Inside db 72 °F
 Design TD 46 °F

Summer Design Conditions

Outside db 95 °F
 Inside db 75 °F
 Design TD 20 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 41 gr/lb

Heating Summary

Structure 13589 Btuh
 Ducts 0 Btuh
Central vent (45 cfm) 2267 Btuh
Outside air
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 15856 Btuh

Sensible Cooling Equipment Load Sizing

Structure 11026 Btuh
 Ducts 0 Btuh
Central vent (45 cfm) 967 Btuh
Outside air
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 1.00
 Equipment sensible load 11956 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	1007	1007
Volume (ft ³)	8052	8052
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	75	48

Latent Cooling Equipment Load Sizing

Structure 1927 Btuh
 Ducts 0 Btuh
Central vent (45 cfm) 1233 Btuh
Outside air
 Equipment latent load 3160 Btuh
Equipment Total Load (Sen+Lat) 15116 Btuh
 Req. total capacity at 0.70 SHR 1.4 ton

Heating Equipment Summary

Make Smart Comfort
 Trade
 Model
 AHRI ref

Efficiency 100 EFF
 Heating input 10.0 kW
 Heating output 34121 Btuh
 Temperature rise 40 °F
 Actual air flow 780 cfm
 Air flow factor 0.057 cfm/Btuh
 Static pressure 0.30 in H2O
 Space thermostat

Cooling Equipment Summary

Make Smart Comfort
 Trade 15 SEER2 AC
 Cond R4A5S24*K*WAA*
 Coil FEVA0024***+NAVA43601CK
 AHRI ref 0
 Efficiency 13.0 EER2, 15.5 SEER2
 Sensible cooling 16380 Btuh
 Latent cooling 7020 Btuh
 Total cooling 23400 Btuh
 Actual air flow 780 cfm
 Air flow factor 0.071 cfm/Btuh
 Static pressure 0.30 in H2O
 Load sensible heat ratio 0.79

Bold/italic values have been manually overridden


957-5402.4.4

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



APPROVED BY
NIA INC. 10/18/2023
FEDERAL MANUFACTURED HOME
CONSTRUCTION AND SAFETY STANDARDS

Level 1



957-5402.4.5

Job #: 5402(P)
Performed by CLAYTON ROCKWELL for:
5402(P)
ROCKWELL, NC

Scale: 1 : 110
Page 1
Right-Suite© Universal 2023
23.0.04 RSU28035
2023-Oct-11 09:45:40
R:\WRITESOFT\MODELS\5402(P).ru

Project Information

For: 5402(P), CLAYTON 957
 ROCKWELL, NC

Notes: DUCT COOLING CAPACITY = 26,000 BTU/HR

APPROVED BY



Design Information

Weather: Fort Bragg/Simmons, NC, US

Winter Design Conditions

Outside db 26 °F
 Inside db 70 °F
 Design TD 44 °F

Summer Design Conditions

Outside db 95 °F
 Inside db 75 °F
 Design TD 20 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 41 gr/lb

Heating Summary

Structure 12739 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **2892** Btuh
Outside air
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 15630 Btuh

Sensible Cooling Equipment Load Sizing

Structure 11105 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **1289** Btuh
Outside air
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 1.00
 Equipment sensible load 12357 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	990	990
Volume (ft ³)	8239	8239
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	68	38

Latent Cooling Equipment Load Sizing

Structure 1847 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **1644** Btuh
Outside air
 Equipment latent load 3490 Btuh
Equipment Total Load (Sen+Lat) 15847 Btuh
 Req. total capacity at 0.70 SHR 1.5 ton

Heating Equipment Summary

Make Smart Comfort
 Trade
 Model
 AHRI ref
 Efficiency 100 EFF
 Heating input 10.0 kW
 Heating output 34121 Btuh
 Temperature rise 40 °F
 Actual air flow 780 cfm
 Air flow factor 0.061 cfm/Btuh
 Static pressure 0.30 in H2O
 Space thermostat

Cooling Equipment Summary

Make Smart Comfort
 Trade 15 SEER2 AC
 Cond R4A5S24*K*WAA*
 Coil FEVA0024***+NAVA43601CK
 AHRI ref 0
 Efficiency 13.0 EER2, 15.5 SEER2
 Sensible cooling 16380 Btuh
 Latent cooling 7020 Btuh
 Total cooling 23400 Btuh
 Actual air flow 780 cfm
 Air flow factor 0.070 cfm/Btuh
 Static pressure 0.30 in H2O
 Load sensible heat ratio 0.78

957-5402.4.6

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.




APPROVED BY



10/18/2023

FEDERAL MANUFACTURED HOME
CONSTRUCTION AND SAFETY STANDARDS

Level 1



957-5402.4.7

Job #: 5402_2BR_OPT(P)
Performed by CLAYTON ROCKWELL for:
5402_2BR_OPT(P)
ROCKWELL, NC

Scale: 1 : 110
Page 1
Right-Suite© Universal 2023
23.0.04 RSU28035
2023-Oct-11 07:33:08
...omes\Desktop\5402_2BR_OPT(P).r

Project Information

For: 5402_2BR_OPT(P), CLAYTON 957
 ROCKWELL, NC

Notes: DUCT COOLING CAPACITY = 26,000 BTU/HR

APPROVED BY



Design Information

Weather: Fort Bragg/Simmons, NC, US

Winter Design Conditions

Outside db 26 °F
 Inside db 70 °F
 Design TD 44 °F

Summer Design Conditions

Outside db 95 °F
 Inside db 75 °F
 Design TD 20 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 41 gr/lb

Heating Summary

Structure 13001 Btuh
 Ducts 0 Btuh
Central vent (45 cfm) **2169** Btuh
Outside air
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 15170 Btuh

Sensible Cooling Equipment Load Sizing

Structure 11026 Btuh
 Ducts 0 Btuh
Central vent (45 cfm) **967** Btuh
Outside air
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 1.00
 Equipment sensible load 11956 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	1007	1007
Volume (ft ³)	8052	8052
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	75	48

Latent Cooling Equipment Load Sizing

Structure 1927 Btuh
 Ducts 0 Btuh
Central vent (45 cfm) **1233** Btuh
Outside air
 Equipment latent load 3160 Btuh
Equipment Total Load (Sen+Lat) 15116 Btuh
 Req. total capacity at 0.70 SHR 1.4 ton

Heating Equipment Summary

Make Smart Comfort
 Trade
 Model
 AHRI ref

Efficiency 100 EFF
 Heating input 10.0 kW
 Heating output 34121 Btuh
 Temperature rise 40 °F
 Actual air flow 780 cfm
 Air flow factor 0.060 cfm/Btuh
 Static pressure 0.30 in H2O
 Space thermostat


Cooling Equipment Summary

Make Smart Comfort
 Trade 15 SEER2 AC
 Cond R4A5S24*K*WAA*
 Coil FEVA0024***+NAVA43601CK
 AHRI ref 0
 Efficiency 13.0 EER2, 15.5 SEER2
 Sensible cooling 16380 Btuh
 Latent cooling 7020 Btuh
 Total cooling 23400 Btuh
 Actual air flow 780 cfm
 Air flow factor 0.071 cfm/Btuh
 Static pressure 0.30 in H2O
 Load sensible heat ratio 0.79

957-5402.4.8

Bold/italic values have been manually overridden


Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



APPROVED BY

NIA 10/18/2023
INC.
FEDERAL MANUFACTURED HOME
CONSTRUCTION AND SAFETY STANDARDS

Level 1



957-5402.4.9

Job #: 5402(OVERHEAD)
Performed by CLAYTON ROCKWELL for:
5402(OVERHEAD)
ROCKWELL, NC

Scale: 1 : 110
Page 1
Right-Suite© Universal 2023
23.0.04 RSU28035
2023-Oct-11 09:47:33
R:\WRITESOFT\MODELS\5402(OVHD

Project Information

For: 5402(OVERHEAD), CLAYTON 957
 ROCKWELL, NC

Notes: DUCT COOLING CAPACITY = 26,000 BTU/HR

APPROVED BY



Design Information

Weather:

Winter Design Conditions

Outside db 28 °F
 Inside db 70 °F
 Design TD 42 °F

Summer Design Conditions

Outside db 95 °F
 Inside db 75 °F
 Design TD 20 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 34 gr/lb

Heating Summary

Structure 12022 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **2731** Btuh
Outside air
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 14753 Btuh

Sensible Cooling Equipment Load Sizing

Structure 11101 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **1303** Btuh
Outside air
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 1.00
 Equipment sensible load 12392 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	990	990
Volume (ft ³)	8239	8239
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	68	38

Latent Cooling Equipment Load Sizing

Structure 1682 Btuh
 Ducts 0 Btuh
Central vent (60 cfm) **1385** Btuh
Outside air
 Equipment latent load 3067 Btuh
Equipment Total Load (Sen+Lat) 15460 Btuh
 Req. total capacity at 0.70 SHR 1.5 ton

Heating Equipment Summary

Make Smart Comfort
 Trade
 Model
 AHRI ref

Efficiency 100 EFF
 Heating input 10.0 kW
 Heating output 34121 Btuh
 Temperature rise 40 °F
 Actual air flow 780 cfm
 Air flow factor 0.065 cfm/Btuh
 Static pressure 0.30 in H2O
 Space thermostat

Cooling Equipment Summary

Make Smart Comfort
 Trade 15 SEER2 AC
 Cond R4A5S24*K*WAA*
 Coil FEVA0024**+NAVA43601CK
 AHRI ref 0
 Efficiency 13.0 EER2, 15.5 SEER2
 Sensible cooling 16380 Btuh
 Latent cooling 7020 Btuh
 Total cooling 23400 Btuh
 Actual air flow 780 cfm
 Air flow factor 0.070 cfm/Btuh
 Static pressure 0.30 in H2O
 Load sensible heat ratio 0.80

957-5402.4.10


Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



APPROVED BY
NIA INC. 10/18/2023
FEDERAL MANUFACTURED HOME
CONSTRUCTION AND SAFETY STANDARDS

Level 1



957-5402.4.11

Job #: 5402_2BR(OVERHEAD)
Performed by CLAYTON ROCKWELL for:
5402_2BR(OVERHEAD)
ROCKWELL, NC

Scale: 1 : 110
Page 1
Right-Suite© Universal 2023
23.0.04 RSU28035
2023-Oct-11 09:02:07
...ODELS\5402_2BR_OPT(OVERHEA

Project Information

For: 5402_2BR(OVERHEAD), CLAYTON 957
 ROCKWELL, NC

Notes: DUCT COOLING CAPACITY = 26,000 BTU/HR

APPROVED BY



Design Information

Weather:

Winter Design Conditions

Outside db 28 °F
 Inside db 70 °F
 Design TD 42 °F

Summer Design Conditions

Outside db 95 °F
 Inside db 75 °F
 Design TD 20 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 34 gr/lb

Heating Summary

Structure 12162 Btuh
 Ducts 642 Btuh
Central vent (45 cfm) **2048** Btuh
Outside air
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 14853 Btuh

Sensible Cooling Equipment Load Sizing

Structure 10985 Btuh
 Ducts 530 Btuh
Central vent (45 cfm) **978** Btuh
Outside air
 Blower 0 Btuh
 Use manufacturer's data n
 Rate/swing multiplier 1.00
 Equipment sensible load 12480 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

	Heating	Cooling
Area (ft ²)	990	990
Volume (ft ³)	7920	7920
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	74	48

Latent Cooling Equipment Load Sizing

Structure 1709 Btuh
 Ducts 113 Btuh
Central vent (45 cfm) **1039** Btuh
Outside air
 Equipment latent load 2861 Btuh
Equipment Total Load (Sen+Lat) 15341 Btuh
 Req. total capacity at 0.70 SHR 1.5 ton

Heating Equipment Summary

Make Smart Comfort
 Trade
 Model
 AHRI ref

Efficiency 100 EFF
 Heating input 10.0 kW
 Heating output 34121 Btuh
 Temperature rise 40 °F
 Actual air flow 780 cfm
 Air flow factor 0.061 cfm/Btuh
 Static pressure 0.30 in H2O
 Space thermostat

Cooling Equipment Summary

Make Smart Comfort
 Trade 15 SEER2 AC
 Cond R4A5S24*K*WAA*
 Coil FEVA0024***+NAVA43601CK
 AHRI ref 0

Efficiency 13.0 EER2, 15.5 SEER2
 Sensible cooling 16380 Btuh
 Latent cooling 7020 Btuh
 Total cooling 23400 Btuh
 Actual air flow 780 cfm
 Air flow factor 0.068 cfm/Btuh
 Static pressure 0.30 in H2O
 Load sensible heat ratio 0.81

957-5402.4.12

Bold/italic values have been manually overridden

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.